

FAIRFAX WATER
8560 Arlington Boulevard
Fairfax, Virginia 22031
(703) 289-6300

March 5, 2007

MEMORANDUM

TO: Distribution

FROM: Kathryn D. Smedley, P.E., Manager, Design & Construction

SUBJECT: Updated Painting Requirements for Hydrants, Guard Posts, and Water Main within Vaults

Fairfax Water does not paint new hydrants, guard posts, or water mains within vaults installed by others. This painting will need to be completed by the installer prior to Final Acceptance by Fairfax Water of a subdivision or project. Paint shall be applied in accordance with the approved manufacturer's procedures and in accordance with Section 09900 Special Coatings of the Fairfax Water's Water Main Installation and Service Contract dated March 2006. The appropriate paints are shown below:

Hydrants

Barrel - Duron DTM Gloss Chinese Red Paint (#601834864, this number provided for your reference only, subject to change)

Top & Caps - Duron Duraclad Ready Mix Aluminum Paint (#601839327, this number provided for your reference only, subject to change)

Guard Posts for Test Stations

Primer - Dupont 25P Primer - Meadow Green, #67642, 1 coat

Top Coat - Dupont 333 Urethane - Imron Terra Green, #67639, 1 coat

Guard Posts for Fire Hydrants

Primer - Duraclad Primer (any), 1 coat


Top Coat - DTM OSHA Safety Blue, 1 coat

Water Mains within Vaults

Primer - Dupont 25P Primer - Meadow Green, #67642, 2 coats

Top Coat - none

If you have any questions, feel free to contact the Fairfax Water Construction Department at (703)289-6388 or 6389.



Kathryn D. Smedley, P.E.
Manager, Design & Construction